



## LOLER Proof of Load or Pull Test NDT Certification

This report complies with the requirements of the Lifting Operations and Lifting Equipment Regulations 1998.


Date of testing: 02 DEC 2020	Date of report: 04 DEC 2020	Report number: HPP STRPH
------------------------------	-----------------------------	--------------------------

Name & address for whom the testing was made: Cirque de Silk Crispin Hall 83 High Street Street Somerset BA16 0EZ	Address of premises at which test was made: Cirque de Silk Crispin Hall 83 High Street Street Somerset BA16 0EZ
---	---

Description & identification of the equipment:	WLL in kg or MBL in kN	Year of manufacture if known:	Date of last test if known:
I Beam configuration installed to structural engineers specification.			
Beam A Pre 3.77 During 3.77 Post 3.77m	200KG per point or 400KG UDL	2020	N/A
Beam B Pre 3.76 During 3.76 Post 3.76m	200KG per point or 400KG UDL	2020	N/A
Beam C Pre 3.78 During 3.78 Post 3.78	200KG per point or 400KG UDL	2020	N/A

<div>Is this the first test after installation Or after assembly at a new site or location?</div> <table><tr><td>YES</td><td>x</td><td>NO</td><td></td></tr></table> <div>If the answer to the above question is YES Was test a proof of load or pull test?</div> <table><tr><td>Proof of Load</td><td>X</td><td>Pull Test</td><td></td></tr></table>	YES	x	NO		Proof of Load	X	Pull Test		<div>Applied load during normal use:</div> <div>Applied load during testing: 600KG per beam</div> <div>Post load deformation: NO See measurements above</div>
YES	x	NO							
Proof of Load	X	Pull Test							
<div>Proof of Load or pull test duration per point: 5 minutes</div>	<div>Pull Tester within calibration period: N/A</div>								

**Components used in testing:** 2 x Stillages with 300KG weights Stillage Lever chain hoist shackles slings and carabineers. Load cells used to confirm load as above.

Name of the person making this report:  Jonathan Hull	Name of person authenticating this report:  Jonathan Hull  Signature: 	Date:  4 DEC 2020
Name and address of employer of persons making and authenticating this report: <b>High Performance Rigging Ltd, Little Swattesfield Hall, Eye, Suffolk IP23 8HH</b>		

